

Lawton Adams Construction Co.
 260 Route 100 Somers, NY 10589
 (914) 232-3275

Sieve Analysis Report

Sample ID	17404	Notes:				
Sample Date	7/28/2025					
Weather	N/A					
Collection Point	Sample Bag					
Material	1 1/2" WASHED GRAVEL					
Method	Dry					
Standard Spec	1 1/2" Washed	FM:	0.27	AFS:	2.20	
Sieve Size		Weight	Percent Retained	Cumulative % Passing	Cumulative % Retained	Spec Limits
US	MM					
2-1/2 in.	63mm	0	.00	100.0	.0	100
2 in.	50mm	0	.00	100.0	.0	90-100
1-1/2 in.	37.5mm	168.55	27.46	72.5	27.5	35-70
1/2 in.	12.7mm	440.75	71.81	.7	99.3	0-5
Pan	0mm	4.5	.73	.0	100.0	0
Total:		613.8	Sample Wt	613.65	% Diff	0.02444

