



Quality Test Report

Product 1313-1 1/2" (37.5mm) Stone
Specification NYSDOT # 3 Stone

Sample Information

Sample No 1765683428 **Split Sample**
Date Sampled 03/19/2026 16:11 **Resample**
Type Investigative
Method Stockpile

Gradation Results

Date Completed 03/19/2026 16:11

Unit	Moist Mass	Dry Mass	Wash Mass	Moisture %	Wash Loss %	Procedure								
g		4023.70				Sieve	Mass Retained	Cum Mass Retained	Ind % Retained	% Retained	% Passing	Target	Specification	Comment
						3" (75mm)								
						2 1/2" (63mm)	0.00	0.00	0	0	100		100-100	
						2" (50mm)	0.00	0.00	0	0	100		90-100	
						1 1/2" (37.5mm)	1906.10	1906.10	47	47	53		35-70	
						1" (25mm)	1735.10	3641.20	43	90	10		0-15	
						3/4" (19mm)	298.30	3939.50	7	98	2			
						1/2" (12.5mm)	43.50	3983.00	1	99	1			
						#200 (75µm)	14.40	3997.40	0.4	99.3	0.7		0-0.7	
						Pan	24.80	4022.20	0.7	100.0	0.0			